

**SUPPLEMENTAL BID BULLETIN**

**Republic of the Philippines  
PHILIPPINE INTERNATIONAL CONVENTION CENTER  
PICC Complex, 1307 Pasay City  
BIDS AND AWARDS COMMITTEE (BAC)**

May 14, 2024

**SUPPLY AND DELIVERY OF VARIOUS MECHANICAL SUPPLIES, PARTS AND  
MATERIALS**

**ADDENDUM NO. 01**

This Addendum is issued to amend/revise certain provisions of the Bid Documents for the above-captioned procurement. Said amendments are as follows:

I. Section V- Special Conditions of the Contract have been revised to read as follows:

- GCC Clause 5
  - Warranty period
    - Ninety (90) **calendar** days warranty after acceptance by the PICC authorized representative of the delivered Goods.

The obligation for the warranty shall be covered by either retention money in an amount equivalent to five percent (5%) of the total contract price, or a special bank guarantee & equivalent to five percent (5%) of the total contract price. (Note: GPPB RES NO. 30-2017).

The said amount shall be released after the lapse of the warranty period or after consumption thereof, provided, that the supplies delivered are free from patent and latent defects and all the conditions imposed under the contract have been fully met.

II. Section VI- Schedule of Requirements have been changed to read as:

- LOT V
  - Full delivery within **one hundred twenty (120)** calendar days from receipt of Notice to Proceed

III. Section VII- Technical Specifications have been revised to read as follows:

- **Lot I – EQUIPMENT CONTROL COMPONENTS**

- Item No. 2

- THERMAL OVERLOAD RELAY, BRAND ALLEN BRADLEY, 193-BSC 24, UI 600V, CURRENT RANGE 16-24A or its equivalent.

- **Lot IV – MATERIALS/EQUIPMENT FOR VARIOUS MECHANICAL WORKS**

Item	Qty.	Unit	Specification
19	5	BOX	THHN WIRE #08, STRANDED, COPPER, AT LEAST WITH PS MARK
20	5	BOX	THHN WIRE #10, STRANDED, COPPER, AT LEAST WITH PS MARK
21	5	BOX	THHN WIRE #12, STRANDED, COPPER, AT LEAST WITH PS MARK
22	5	BOX	THHN WIRE #14, STRANDED, COPPER, AT LEAST WITH PS MARK
31	5	unit	MAIN CONTACTOR, TYPE GCA-530 COIL 440V 460V/200HP WESTINGHOUSE BRAND OR ITS EQUIVALENT

- **Lot V – YORK CHILLERS CONSUMNABLE MATERIALS**

Item	Qty.	Unit	Specification
4	2	Unit	CONTROL TRIGGER BOARD; 371-01450-002
10	2	Unit	OIL PUMP, PN.026-28513-000
19	3	pail	YORK "C" OIL

The corrected copies are attached. Bidders are advised to replace their original copies with the corrected copies.

For guidance and information of all concerned.

  
**MELPIN A. GONZAGA**  
 Chairman

Received by:

\_\_\_\_\_  
 (Signature over printed name)

Telephone/Fax No. \_\_\_\_\_

Date: \_\_\_\_\_

Name of Company: \_\_\_\_\_

5	<p>Warranty period</p> <p>Ninety (90) <i>calendar</i> days warranty after acceptance by the PICC authorized representative of the delivered Goods.</p> <p>The obligation for the warranty shall be covered by either retention money in an amount equivalent to five percent (5%) of the total contract price, or a special bank guarantee &amp; equivalent to five percent (5%) of the total contract price. (Note: GPPB RES NO. 30-2017.</p> <p>The said amount shall be released after the lapse of the warranty period or after consumption thereof, provided, that the supplies delivered are free from patent and latent defects and all the conditions imposed under the contract have been fully met.</p>
6	<p>The period for correction of defects is seven (7) calendar days upon receipt of notice from PICC project-in-charge.</p>

## *Section VI. Schedule of Requirements*

The delivery schedule expressed as weeks/months stipulates hereafter a delivery date which is the date of delivery to the project site.

Item Number	Description	Delivered, Weeks/Months
LOT I	EQUIPMENT PARTS AND CONTROL COMPONENTS	Full delivery within ninety (90) calendar days from receipt of Notice to Proceed
LOT II	AIRCONDITIONING CONSUMABLES	Full delivery within one ninety (90) calendar days from receipt of Notice to Proceed
LOT III	SEWAGE TREATMENT PLANT CONSUMABLES	Full delivery within ninety (90) calendar days from receipt of Notice to Proceed
LOT IV	MATERIALS/EQUIPMENT FOR VARIOUS MECHANICAL WORKS	Full delivery within ninety (90) calendar days from receipt of Notice to Proceed
LOT V	YORK CHILLERS CONSUMABLES MATERIALS	Full delivery within <i>one hundred twenty (120)</i> calendar days from receipt of Notice to Proceed

I hereby commit to comply and deliver all the above requirements in accordance with the above stated schedule.

\_\_\_\_\_  
Name of Company / Bidder

\_\_\_\_\_  
Signature over printed Name of Authorized Representative

\_\_\_\_\_  
Position

\_\_\_\_\_  
Date

# Technical Specifications

Item	Qty.	Unit	Specification	Statement of Compliance
<b>Lot I – EQUIPMENT CONTROL COMPONENTS</b>				
			FOR MR-1 A/C SYSTEM	
1	7	UNIT	THERMAL EXPANSION VALVE, BRAND DANFOSS, TGEX 30TR 104KW, -40/+10 deg.C, R-22	
2	7	PC	THERMAL OVERLOAD RELAY, BRAND ALLEN BRADLEY, 193-BSC 24, Ui 600V, CURRENT RANGE 16-24A. <i>or its equivalent</i>	
3	7	PC	TIMER RELAY, TYPE CSF-D, X1M, CONTACT RATING: AC 250V, 5A, 8-PIN	
4	7	PC	TIMER RELAY, TYPE CSF-D, 30S, CONTACT RATING: AC 250V, 5A, 8-PIN	
5	7	PC	TIMER RELAY, TYPE CSG-C, 03S, CONTACT RATING: AC 250V, 5A, 8-PIN	
6	7	PC	TIMER RELAY, TYPE CSG-C, 03M, CONTACT RATING: AC 250V, 5A, 8-PIN	
7	7	PC	PHASE RELAY, BRAND FOTEK, MODEL PR-1-440V, 440VAC, 60Hz	
8	7	PC	RELAY, MODEL HC4-H-AC240V, AP3148K, 5A 1/10HP 125,250V AC	
9	4	Unit	POWER TRANSFORMER, INPUT VOLTAGE 240/480V, OUTPUT VOLTAGE 120/240V, CAPACITY 250VA, 1-PHASE, 60HZ, CLASS 1	
10	7	Unit	TIMER RELAY, STAR-DELTA TIMER, BRAND ANLY, TYPE TRD-N, 220VAC, RANGE 0-30SEC.	
11	7	Unit	OVERLOAD RELAY, TYPE TR-N2/3, 220VAC, RANGE 24-36A	
12	10	Unit	MAGNETIC CONTACTOR, BRAND FUJI, TYPE SC-5-1	
13	4	Unit	CIRCUIT BREAKER, BRAND SCHNEIDER ELECTRIC, 60A CAPACITY, 3 POLE	
14	4	Unit	CIRCUIT BREAKER, BRAND SCHNEIDER ELECTRIC, 20A CAPACITY, 3 POLE (SEE SAMPLE)	
15	4	PC	RUBBER FLEXIBLE JOINT CONNECTOR, BRAND TOZEN TWINFLEX, 150 (6)	
16			<i>FOR FORUM A/C SYSTEM</i>	
17	10	pc	CIRCUIT BREAKER, 125A CAPACITY, 3-POLE 500V / 60HZ, BRAND ABB /equivalent	
18	10	pc	FAN MOTOR, BRAND CARRIER, 2HP, POLE 4, VOLT 230, HZ 60, PH-3, RPM 1730, , CURRENT 6.3A, PART NO. HD56DL851	
19	15	pc	FAN MOTOR, BRAND CARRIER, 1/3HP, POLE 6, VOLT 208/230, HZ 60, PH-1, RPM 900/950, CAPACITOR 7.5UF/440VAC, CURRENT 1.62/1.70A, PART NO. PE740095	
20	10	Unit	MAGNETIC CONTACTOR, BRAND FUJI, TYPE SC-N3, 220VAC, 60HZ	
21	4	PC	THERMAL OVERLOAD RELAY, TYPE TR-N3/3, 220VAC, RANGE 24-36A	
22	15	PC	COMPRESSOR RELAY, HN61KK913, COIL 208/240V, 60HZ	
23	25	PC	BLOWER WHEEL, SQUIRREL CAGE TYPE, Diameter: 10.5 inches , Length: 10.5 inches	
24	15	pc	FAN CAPACITOR, 7.5UF, 440VAC, 60Hz	

13	20	KILO	MULTI PURPOSE ROUND RAGS
14	10	UNIT	PVC PIPE CONNECTOR (BLUE), 2 INCH DIA.
<b>Lot IV – MATERIALS/EQUIPMENT FOR VARIOUS MECHANICAL WORKS</b>			
1	1	SET	PORTABLE PRESSURE WASHER, HEAVY DUTY, 60-100 BAR, 220V, 60HZ, COMPLETE ACCESSORIES
2	1	SET	ROTARY HAMMER DRILL, Heavy Duty, Power Rating: 230V, 710Watts, 1050rpm, Drilling Dia. Range: 5/32 to 1 3/32 in., with masonry drill bit, 1-pc. 1/2" dia. X 18" L & 1-pc. 3/4"dia. X 18" L.
3	3	SET	UNIVERSAL DRILL BIT, HEAVY DUTY, FOR MASONRY-METAL-WOOD, SIZES 3mm (1-pc.), 4mm (1-pc.), 5mm (1-pc.), 6mm (1-pc.), 7mm (1-pc.), 8mm (1-pc.) / Each Type.
4	4	UNIT	CIRCUIT BREAKER, 100Amp. Capacity, 3-pole
5	4	UNIT	CIRCUIT BREAKER, 75Amp. Capacity, 3-pole
6	4	UNIT	CIRCUIT BREAKER, 60Amp. Capacity, 3-pole
7	20	SET	GLASS DOOR PIVOT HINGE (STAINLESS 304) MECHANISM, BEARING TYPE
8	2	SET	UNIVERSAL JOINT MECHANISM, (AS PER SAMPLE)
9	2	SET	UNIVERSAL JOINT MECHANISM, (AS PER SAMPLE)
10	8	pcs	FAN V-BELT B-136 (MULTI -BELT TYPE x 5 GROOVES)
11	24	pcs	AMEREX GLOBE® K 450F Fusible Link
12	10	pcs	AMEREX, N2 ACTUATOR CYLINDER, PART NO. 12856, 10 CU. IN.
13	20	UNIT	10 LBS. PORTABLE FIRE EXTINGUISHER - CLASS "K"
14	20	UNIT	DRAIN PUMP, For DAIKIN BRAND CELING CASSETTE TYPE FAN COIL UNITS
15	20	UNIT	DRAIN PUMP, For DAIKIN CEILING SUSPENDED TYPE FCU, BRAND KINGPUMP, 220V, 18W, 0.1A, 60HZ, 3M HEAD
16	10	METER	CANVASS CLOTH, 1METER WIDTH
17	20	UNIT	WIRED REMOTE CONTROLLER, MODEL BRC1E62, BRAND DAIKIN
18	20	UNIT	WIRED REMOTE CONTROLLER, MODEL BRC1C62-9, BRAND DAIKIN
19	5	BOX	THHN WIRE #08, STRANDED, <i>Copper, at least with PS Mark</i>
20	5	BOX	THHN WIRE #10, STRANDED, <i>Copper, at least with PS Mark</i>
21	5	BOX	THHN WIRE #12, STRANDED, <i>Copper, at least with PS Mark</i>
22	5	BOX	THHN WIRE #14, STRANDED, <i>Copper, at least with PS Mark</i>
23	6	TANK	NITROGEN, gas only (refill)
24	3	TANK	ACETYLENE, gas only (refill)
25	3	TANK	OXYGEN, gas only (refill)
26	20	KILO	WELDING ROD 6013 2.5x325mm
27	20	KILO	WELDING ROD 6011 2.5x325mm.
28	100	PC	SILVER ROD, 1/8"x16" LENGTH
29	10	BOX	CUTTING DISC, SIZE 100mmx1.0mmx16mm, 25pcs./BOX
30	10	BOX	GRINDING DISC, SIZE 100mmx6.0mmx16mm, 10pcs./BOX
31	5	unit	MAIN CONTACTOR, TYPE GCA-530 COIL 440V 460V/200HP WESTINGHOUSE BRAND <i>or its equivalent</i>
32	12	PC	BALL BEARING 6203

33	12	PC	BALL BEARING 6307 ZZ
34	12	PC	BALL BEARING 6205 ZZ
35	12	PC	BALL BEARING 6210 ZZ
36	12	PC	BALL BEARING 6310 ZZ-J / C3
37	12	PC	BALL BEARING 6310 ZZ / C3
38	12	PC	BALL BEARING 6311 ZZ
39	12	PC	BALL BEARING 6312 ZZ
40	12	PC	BALL BEARING 6211 CZ
41	8	PC	BALL BEARING 6208 C3
42	12	PC	BALL BEARING 6207 ZZ-J / C3
43	8	PC	BALL BEARING 6207 C3
44	12	PC	BALL BEARING 6309 C3
45	12	PC	BALL BEARING 6209 C3
46	12	SET	PILLOW BLOCK BEARING DVP 14SS11R2, TYPE: ATCS CQM BRAND
47	10	set	PILLOW BLOCK BEARING UK-211 (ASAHI)
48	4	set	PILLOW BLOCK BEARING, P-207
49	20	pcs	HI-TEMP GREASE (1275/NLGI 2) ALMAPLEX
50	2	unit	FLEXIBLE RUBBER CONNECTOR 10" DIA. X 8"LN SINGLE BELLOW WITH FLOATING STEEL FLANGES PN10
51	10	Unit	RUBBER GASKET, 1/8" THICK x 1 METER WIDTH
52	10	Unit	RUBBER GASKET, 1/16" THICK x 1 METER WIDTH
53	10	GAL	PAINT, GRAY COLOR, HIGH TEMPERATURE RESISTANT
54	1	PC	MOTOLITE BATTERY, 8D, TRUCK MASTER, 12V
55	4	PC	BATTERY, 12V, 150Ah@20Hr, 120Ah@5Hr, brand MOTIVE, model T-1275 PLUS, TROJAN
56	6	PC	SOLDERLESS WIRE CONNECTOR, COPPER TYPE, TWO BOLT (for 250mm <sup>2</sup> )
57	6	PC	SOLDERLESS WIRE CONNECTOR, COPPER TYPE, TWO BOLT (for 150mm <sup>2</sup> )
58	4	SET	COUPLING SET, FLANGE TYPE, 47mm and 25mm. SHAFT DIAMETER FOR PACO PUMP AND MOTOR
59	4	unit	TEMPERED GLASS DOOR FOR AUTO SWING DOORS, 12mm THICK (verify actual sample at site)
60	2	PC	GATE VALVE 3" DIA., BRAND CRANE, CLASS 125, CAT. NO. F53, NON RISING STEM, HEAVY DUTY. <i>FOR AIR PURIFIER, BRAND AIRDOG X8, MODEL KJ800F-X8</i>
61	10	UNIT	FILTER
62	10	UNIT	EMITTER WIRES
63	10	UNIT	COLLECTING PLATES
<b>Lot V – YORK CHILLERS CONSUMABLE MATERIALS</b>			
1	2	Unit	DISPLAY BOARD, PN.031-00775-001
2	2	Unit	DISPLAY BOARD, PN.331-01771-000
3	2	Unit	CONTROL LOGIC BOARD; 031-01080-000
4	2	Unit	CONTROL TRIGGER BOARD; 371-01450-002
5	3	Unit	CIRCULATING PUMP KIT, PN.326-33850-000
6	2	Unit	KEYPAD; 024-25258-000

7	2	Unit	KEYPAD; 024-30993-000
8	2	Unit	OIL HEATER, PN.025-29119-000
9	2	Unit	OIL HEATER, PN.025-09445-000
10	2	unit	OIL PUMP, PN.026-28513-000
11	3	Unit	FILTER DRIER/FOUL GAS DML-053, PN.029-21710-000
12	3	Unit	FILTER DRIER/SUCTION SF-28H13
13	4	PC	OIL FILTER ELEMENT; 026-32831-000
14	3	Unit	POTENTIOMETER FLEXIBLE COUPLING; 015-02359-013
15	2	Unit	POWER SUPPLY BOARD; 031-01080-000
16	3	Unit	SENSOR TEMPERATURE (CHW), PN.025-29964-000
17	3	Unit	SENSOR TEMPERATURE (COW), PN.025-28935-000
18	3	unit	WIRE HARNESS 12", PN.571-03774-272
19	3	pail	<b>YORK "C" OIL</b>

**STATEMENT OF COMPLIANCE**

*Bidders must state here either "Comply" or "Not Comply" against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered.*

Note:

*Statements of "Comply" or "Not Comply" must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer's un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidder's statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the applicable laws and issuances.*